



## EC - TYPE EXAMINATION CERTIFICATE

### Equipment or Protective System Intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

- 1
- 2
- 3 EC - Type Examination Certificate Number: **Baseefa02ATEX0224X**
- 4 Equipment or Protective System: **A TYPE XB4 BEACON**
- 5 Manufacturer: **MEDC Limited**
- 6 Address: **Colliery Road, Pinxton, Nottingham, NG16 6JF**
- 7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- 8 Baseefa (2001) Ltd. Notified body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.
- The examination and test results are recorded in confidential Report No. 02(C)0259
- 9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
- EN 50014: 1997 + Amendments 1 and 2      EN 50018: 2000 + Amendment 1      EN 50019: 2000**
- except in respect of those requirements listed at item 18 of the Schedule.
- 10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- 11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- 12 The marking of the equipment or protective system shall include the following :

 **II 2 G EEx d IIC T5**

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa (2001) Ltd. Customer Reference No. 0676

Project File No. 02/0259

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

### Baseefa (2001) Ltd.

Health and Safety Laboratory Site, Harpur Hill,  
Buxton, Derbyshire SK17 9JN  
Telephone +44 (0) 1298 28255 Fax +44 (0) 1298 28216  
e-mail [info@baseefa2001.biz](mailto:info@baseefa2001.biz) web site [www.baseefa2001.biz](http://www.baseefa2001.biz)  
Registered in England No. 4305578 at 13 Dovedale Crescent, Buxton,  
Derbyshire, SK17 9BJ

**R S SINCLAIR**  
**DIRECTOR**  
On behalf of  
Baseefa (2001) Ltd.



## Schedule

### 15 Description of Equipment or Protective System

A TYPE XB4 BEACON rated up to 254V a.c., 50Hz comprises a circular base and cover assembly manufactured in aluminium alloy. The cover incorporates a cemented well glass, forms a tapered spigot joint with the base and is secured with three M8, 25mm long socket head cap screws of minimum grade A4-80.

The beacon is fitted with two xenon lamps each rated at 10J and associated printed circuit board mounted control gear.

An additional printed circuit board may be fitted to allow the control of the beacon by telephone.

Alternative control gear may be fitted to allow the beacon to be used up to 110V d.c. The certification parameters for the XB4 Beacon are given in Table 1 below:-

Internal and external earth facilities are provided.

Cable entry holes are provided as specified on the certified drawings for the accommodation of flameproof cable entry devices, with or without the interposition of a flameproof thread adapter. Unused entries are to be fitted with suitable certified flameproof stopping plugs.

The cable entry devices, thread adapters and stopping plugs shall be suitable for the equipment, the cable and the conditions of use and shall be certified as Equipment (not a Component) under an EC Type Examination Certificate to Directive 94/9/EC.

If the unit is intended for use in a dust atmosphere these devices must be sealed in accordance with the relevant codes of practice to ensure a dust tight seal.

Table 1

TYPE DESIGNATION	VOLTAGE RATINGS (V)	MAXIMUM POWER RATING	TEMPERATURE CLASSIFICATION	AMBIENT TEMPERATURE RANGE	DELAY ON OPENING (MINUTES)
XB4 (XENON LAMP)	110, 120, 220, 240, 254 A.C.	2 x 10J	T5	-20°C to +40°C	20
XB4 (XENON LAMP)	24, 48, 110 D.C.	2 x 10J	T5	-20°C to +40°C	20
XB4 (XENON LAMP)	110, 120, 220, 240, 254 A.C.	2 x 10J	T4	-55°C to +55°C	20
XB4 (XENON LAMP)	24, 48, 110 D.C.	2 x 10J	T4	-55°C to +55°C	20

### VARIATION 0.1

The XB4 lamp and control gear may be replaced with alternative assemblies to form the types of beacons with certification parameters as listed in Table 2:-



Table 2

TYPE DESIGNATION	VOLTAGE RATINGS (V)	MAXIMUM WATTAGE RATING	TEMPERATURE CLASSIFICATION	AMBIENT TEMPERATURE RANGE	DELAY ON OPENING (MINUTES)
FL4 (FLUORESCENT LAMP)	24, 48, 110 D.C.	13W	T6	-20°C to +40°C	15
FL4 (FLUORESCENT LAMP)	110, 120 A.C.	26W	T4	-20°C to +55°C	15
FL4 (FLUORESCENT LAMP)	220, 240, 254 A.C.	39W	T4	-20°C to +55°C	15
FL4 (FLUORESCENT LAMP)	24, 48, 110 D.C.	13W	T5	-20°C to +55°C	15
FB4 (FILAMENT LAMP)	254 A.C. maximum	100W	T3	-55°C to +55°C	5
FB4 (FILAMENT LAMP)	254 A.C. maximum	60W	T4	-55°C to +55°C	5

#### VARIATION 0.2

Alternative use of stainless steel for the enclosure material.

#### VARIATION 0.3

The beacon may be fitted with a Type GRP Terminal Chamber manufactured by MEDC, as certified under EC-Type Examination Certificate Baseefa02ATEX0223U and coded EEx e II.

A Line Bushing Type 07-91 manufactured by Bartec as certified under EC-Type Examination Certificate (referred to as an EC-Prototype Testing Certificate) PTB 97 ATEX 1047U coded Ex II 2 G EEx d II is incorporated to effect connection from the terminals provided within GRP Terminal Chamber to those within the lamp housing.

This version of the XB4 Beacon fitted with the Type GRP Terminal Chamber is marked:-

Ⓔ II 2 G EEx de IIC

with the temperature classification and other certification parameters as given in Table 3 below:-

Table 3

TYPE DESIGNATION	VOLTAGE RATINGS (V)	MAXIMUM POWER RATING	TEMPERATURE CLASSIFICATION	AMBIENT TEMPERATURE RANGE	DELAY ON OPENING (MINUTES)
XB4 (XENON LAMP)	110, 120, 220, 240, 254 A.C.	2 x 10J	T5	-20°C to +40°C	20
XB4 (XENON LAMP)	24, 48, 110 D.C.	2 x 10J	T5	-20°C to +40°C	20
XB4 (XENON LAMP)	110, 120, 220, 240, 254 A.C.	2 x 10J	T4	-50°C to +55°C	20
XB4 (XENON LAMP)	24, 48, 110 D.C.	2 x 10J	T4	-50°C to +55°C	20
FL4 (FLUORESCENT LAMP)	24, 48, 110 D.C.	13W	T6	-20°C to +40°C	15



TYPE DESIGNATION	VOLTAGE RATINGS (V)	MAXIMUM POWER RATING	TEMPERATURE CLASSIFICATION	AMBIENT TEMPERATURE RANGE	DELAY ON OPENING (MINUTES)
FL4 (FLUORESCENT LAMP)	110, 120 A.C.	26W	T4	-20°C to +55°C	15
FL4 (FLUORESCENT LAMP)	220, 240, 254 A.C.	39W	T4	-20°C to +55°C	15
FL4 (FLUORESCENT LAMP)	24, 48, 110 D.C.	13W	T5	-20°C to +55°C	15
FB4 (FILAMENT LAMP)	254 A.C. maximum	100W	T3	-50°C to +55°C	5
FB4 (FILAMENT LAMP)	254 A.C. maximum	60W	T4	-50°C to +55°C	5

**16 Report Number**

Baseefa Certification Report 02(C)0259

**17 Special Condition for Safe Use**

For replacement purposes the cover fixing screws shall be of stainless steel minimum grade A4-80.

And additionally for the EEx de versions of the beacons:-

- Not more than one single or multiple strand lead shall be connected into either side of any terminal, unless multiple conductors have been joined in a suitable manner, e.g. two conductors into a single insulated crimped boot lace ferrule.
- Leads connected to the terminals shall be insulated for the appropriate voltage and this insulation shall extend to within 1mm of the metal of the terminal throat.
- All terminal screws, used and unused, shall be tightened down.
- When fitting QB insulating combs (cross connecting links) to terminal ways a further single conductor of 1.5mm<sup>2</sup> minimum cross-sectional area may be connected to the same terminal way on top of the prong.
- The inside edge of the insulation of the QB combs cross-connecting arm shall be in contact with the terminal moulding.

**18 Essential Health and Safety Requirements**

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

**19 Drawings and Documents**

Number	Issue	Date	Description
188-547	A	08-12-02	General Arrangement
188-548	A	08-12-02	Internal Arrangements
188-148	C	7.6.96	Circuit Diagram - 24/48/110V DC Xenon Beacon
188-149	B	6.7.93	Circuit Diagram - 110/120V AC Xenon Beacon
188-150	B	6.7.93	Circuit Diagram - 220/240/254V AC Xenon Beacon
188-151	D	05.06.03	Circuit Diagram - DC Fluorescent Beacon
188-152	B	6.7.93	Circuit Diagram - Telephone/Relay/Initiate



**1 SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

**2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

**3 Supplementary EC - Type Examination Certificate Number: Baseefa02ATEX0224X/1**

**4 Equipment or Protective System: A TYPE XB4 BEACON**

**5 Manufacturer: MEDC Limited**

**6 Address: Brookhill Industrial Estate, Colliery Road, Pinxton, Nottingham,  
NG16 6JF**

**7 This supplementary certificate extends EC - Type Examination Certificate No. Baseefa02ATEX0224X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.**

This supplementary certificate shall be held with the original certificate.

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa (2001) Ltd. Customer Reference No. 0676

Project File No. 04/0460

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa (2001) Ltd.**

Health and Safety Laboratory Site, Harpur Hill,  
Buxton, Derbyshire SK17 9JN  
Telephone +44 (0) 1298 28255 Fax +44 (0) 1298 28216  
e-mail [info@baseefa2001.biz](mailto:info@baseefa2001.biz) web site [www.baseefa2001.biz](http://www.baseefa2001.biz)  
Registered in England No. 4305578 at 13 Dovedale Crescent, Buxton,  
Derbyshire, SK17 9BJ

**R S SINCLAIR**  
**DIRECTOR**  
On behalf of  
Baseefa (2001) Ltd.



13

## Schedule

14

Certificate Number Baseefa02ATEX0224X/1

15 Description of the variation to the Equipment or Protective System

### Variation 1.1

The optional addition of a series connected resistor and an end of line resistor each rated at 2.5W minimum and 470Ω minimum fitted across the input terminals for the 24V d.c. versions of the beacons.

16 Report Number

Baseefa Report 04(CI)0460

17 Special Conditions for Safe Use

None additional to those listed previously.

18 Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 Drawings and Documents

Number	Issue	Date	Description
188-548	B	19-05-04	Internal Arrangements



**1 SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

**2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

**3 Supplementary EC - Type Examination Certificate Number: Baseefa02ATEX0224X/2**

**4 Equipment or Protective System: A TYPE XB4 BEACON**

**5 Manufacturer: MEDC Limited**

**6 Address: Brookhill Industrial Estate, Colliery Road, Pinxton, Nottingham,  
NG16 6JF**

**7 This supplementary certificate extends EC - Type Examination Certificate No. Baseefa02ATEX0224X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.**

This supplementary certificate shall be held with the original certificate.

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0676

Project File No. 04/0529

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa (2001) Ltd  
Registered in England No. 4305578 at the above address

**R S SINCLAIR**  
**DIRECTOR**  
On behalf of  
Baseefa (2001) Ltd.



13

## Schedule

14

Certificate Number Baseefa02ATEX0224X/2

15 Description of the variation to the Equipment or Protective System

### Variation 2.1

The optional use of both the EEx d and EEx e versions of the Types XB4, FL4 and FB4 Beacons in a potentially explosive dust atmosphere in accordance with EN 50281-1-1:1998 + Amendment 1.

When this option is invoked a D is added to the marking which takes the form **Ex II 2 GD IIC**

In accordance with the marking requirements for both EN50014 and EN50281-1-1 the maximum surface temperature is marked; T85°C, T100°C, T135°C or T200°C as appropriate and detailed on certificate schedule drawing number 188-548.

The appropriate ambient temperature range in which each of the EEx d versions of the beacon can operate in a potentially explosive dust atmosphere is as follows;

Type XB4 Beacon -55°C to +55°C

Type FB4 Beacon -55°C to +55°C

Type FL4 Beacon -20°C to +55°C

The appropriate ambient temperature range in which each of the EEx de versions of the beacon can operate in a potentially explosive dust atmosphere is as follows;

Type XB4 Beacon -20°C to +55°C

Type FB4 Beacon -20°C to +55°C

Type FL4 Beacon -20°C to +55°C

16 Report Number

Baseefa Certification Report 04(C)0529

17 Special Conditions for Safe Use

Any cable entry device used with the equipment shall be suitable for the entry arrangement and maintain the ingress protection level IP6X.

18 Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 Drawings and Documents

Number	Issue	Date	Description
188-547	B	07-06-05	General Arrangement
188-548 sheet 1	C	21-07-05	Internal Arrangements
188-548 sheet 2	C	21-07-05	Marking Data





**1 SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

**2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

**3 Supplementary EC - Type Examination Certificate Number: Baseefa02ATEX0224X/3**

**4 Equipment or Protective System: A TYPE XB4 BEACON**

**5 Manufacturer: MEDC Limited**

**6 Address: Colliery Road, Brookhill Industrial Estate, Pinxton, Nottingham  
NG16 6JF**

**7 This supplementary certificate extends EC - Type Examination Certificate No. Baseefa02ATEX0224X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.**

This supplementary certificate shall be held with the original certificate.

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0676

Project File No. 05/0833

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa (2001) Ltd  
Registered in England No. 4305578 at the above address

**R S SINCLAIR**  
**DIRECTOR**  
On behalf of  
Baseefa (2001) Ltd.



13

### Schedule

14

Certificate Number Baseefa02ATEX0224X/3

15

#### Description of the variation to the Equipment or Protective System

##### Variation 3.1

Alternative terminal arrangement in the Type FB4 Filament Lamp, incorporating up to twelve type SAK2.5 rail mounted terminals.

16

#### Report Number

None

17

#### Special Conditions for Safe Use

None additional to those listed previously

18

#### Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19

#### Drawings and Documents

Number	Issue	Date	Description
188-548 Sheets 1 & 2	D	22-11-05	Internal Arrangements & Marking



**SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

**Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

- 3 Supplementary EC - Type Examination Certificate Number: **Baseefa02ATEX0224X/4**
- 4 Equipment or Protective System: **A Type XB4 Xenon Beacon**
- 5 Manufacturer: **MEDC Limited**
- 6 Address: **Colliery Road, Pinxton, Nottingham, NG 16 6JF**
- 7 This supplementary certificate extends EC - Type Examination Certificate No. Baseefa02ATEX0224X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0676

Project File No. 06/0680

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa (2001) Ltd  
Registered in England No. 4305578 at the above address

**R S SINCLAIR**  
**DIRECTOR**  
On behalf of  
Baseefa (2001) Ltd.



13

### Schedule

14

**Certificate Number Baseefa02ATEX0224X/4**

15

#### **Description of the variation to the Equipment or Protective System**

##### **Variation 4.1**

To record the following reports which are respectively reproductions of BASEEFA Internal Certification Reports 97(CI)0581, referenced in Certification Report 05(C)0529 which supported Baseefa02ATEX0224X, and 04(CI)0460 which supported Baseefa02ATEX0224X/1; both made suitable for external issue.

16

#### **Report Number**

Baseefa Certification Reports 06(C)0680/1 and 06(C)0680/2

17

#### **Special Conditions for Safe Use**

None additional to those listed previously

18

#### **Essential Health and Safety Requirements**

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19

#### **Drawings and Documents**

None



**1 SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

**2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

**3 Supplementary EC - Type Examination Certificate Number: Baseefa02ATEX0224X/5**

**4 Equipment or Protective System: Type XB4 Xenon Beacon**

**5 Manufacturer: MEDC Limited**

**6 Address: Colliery Road, Pinxton, Nottingham, NG16 6JF**

**7 This supplementary certificate extends EC – Type Examination Certificate No. Baseefa02ATEX0224X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.**

This supplementary certificate shall be held with the original certificate.

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0676

Project File No. 07/0589

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa (2001) Ltd  
Registered in England No. 4305578 at the above address

**R S SINCLAIR**  
**DIRECTOR**  
On behalf of  
Baseefa (2001) Ltd.



---

## Schedule

13

14

Certificate Number Baseefa02ATEX0224X/5

15 **Description of the variation to the Equipment or Protective System**

**Variation 5.1**

Alternative NPT cable entries.

**Variation 5.2**

Minor drawing amendments.

**Variation 5.3**

To confirm that the equipment covered by this certificate has been reviewed against the requirements of EN60079-0: 2006, EN60079-1: 2004, EN60079-7: 2007, EN 61241-0: 2006 and EN 61241-1: 2004 in respect of the differences from the Standards to which this certificate was issued; none of these differences affect these units.

**Variation 5.4**

The Type XB4 Beacon and the Type FB4 Beacon covered by the above variations may be variously coded

⊕ II 2 G Ex d IIC T\* (T<sub>amb</sub> -55°C to +55°C), or

⊕ II 2 G Ex de IIC T\* (T<sub>amb</sub> -50°C to +55°C), or

⊕ II 2 GD Ex d IIC Ex tD A21 IP6X T\*°C (T<sub>amb</sub> -55°C to +55°C), or

⊕ II 2 GD Ex de IIC Ex tD A21 IP6X T\*°C (T<sub>amb</sub> -50°C to +55°C).

\* see original certificate schedules and certification reports for options.

**Variation 5.5**

The Type FL4 Beacon covered by the above variations may be variously coded

⊕ II 2 G Ex d IIC T\* (T<sub>amb</sub> -20°C to +55°C), or

⊕ II 2 G Ex de IIC T\* (T<sub>amb</sub> -20°C to +55°C), or

⊕ II 2 GD Ex d IIC Ex tD A21 IP6X T\*°C (T<sub>amb</sub> -20°C to +55°C), or

⊕ II 2 GD Ex de IIC Ex tD A21 IP6X T\*°C (T<sub>amb</sub> -20°C to +55°C).

\* see original certificate schedules and certification reports for options.

16 **Report Number**

None

17 **Special Conditions for Safe Use**

None additional to those listed previously

18 **Essential Health and Safety Requirements**

Compliance with the Essential Health and Safety Requirements is not affected by this variation.



---

**19 Drawings and Documents**

Number	Sheet	Issue	Date	Description
188-547	1	D	26.09.07	General Enclosure Details
188-548 Sheets 1 & 2	-	E	26.09.07	Internal Arrangements and Marking



- 
- 1           **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**
- 2           **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres**  
              **Directive 94/9/EC**
- 3   Supplementary EC - Type Examination Certificate    **See Schedule**  
      Number:
- 4   Equipment or protective system:                   **See Schedule**
- 5   Manufacturer:                                       **MEDC Limited**
- 6   Address:   **Colliery Road, Pinxton, Nottingham, NG16 6JF**
- 7   This supplementary certificate extends the EC - Type Examination Certificates listed in the Schedule to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedules of the said Certificates but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

A copy of this Supplementary Certificate shall be attached to each of the original Certificates.

This certificate may only be reproduced in its entirety, without any change, Schedule included.

Baseefa Customer Reference No. 0676

Project File No. 08/0067

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa (2001) Ltd  
Registered in England No. 4305578 at the above address

R S SINCLAIR

DIRECTOR  
On behalf of  
Baseefa (2001) Ltd.





## Schedule

### Description of the variation to the Equipment or Protective System

Alternative certification label wording for the units listed below and as on the scheduled drawings.

Certificate No.	Supplement No.	Equipment Type
BAS00ATEX2031	3	Type XB9 Xenon Beacon
BAS00ATEX2097X	10	Type DB3 Sounder and DB4 Speaker Units
BAS00ATEX2204X	2	Type XB10 Beacon
Baseefa02ATEX0224X	6	Type XB4 Xenon Beacon
BAS02ATEX2086X	6	Type DB10 Loudspeaker Units
Baseefa03ATEX0222	4	Type SM87 HXB & SM87 LED Beacons
Baseefa04ATEX0166X	3	Type DB16 IIB Speaker Unit

### Report No.

None

### Special Conditions for Safe Use

None additional to those listed previously

### Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

### Drawings and Documents

Number	Sheet	Issue	Date	Description
227-173	-	A	28-01-08	Type XB9 Xenon Beacon
219-833	-	A	28-01-08	Type DB3 Sounder Units
199-519	-	A	28-01-08	Type DB4 Speaker Units
228-210	-	A	28-01-08	Type XB10 Beacon
188-625	-	A	28-01-08	Type XB4 Xenon Beacon
253-154	-	A	07-01-08	Type DB10 Loudspeaker Units
562-661	-	A	28-01-08	Type SM87 HXB Xenon Beacon
562-662	-	A	28-01-08	Type SM87 LED Beacon
286-145	-	A	07/01/08	Type DB16 IIB Speaker Unit



1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

3 Supplementary EC - Type Examination Certificate Number: **Baseefa02ATEX0224X/7**

4 Equipment or Protective System: **Type XB4 Xenon Beacon**

5 Manufacturer: **Cooper MEDC Limited**

6 Address: **Colliery Road, Pinxton, Nottingham, NG16 6JF**

7 This supplementary certificate extends EC - Type Examination Certificate No. Baseefa02ATEX0224X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 0676

Project File No. 09/0342

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.

**R S SINCLAIR**  
**DIRECTOR**  
On behalf of  
Baseefa



13

### Schedule

14

Certificate Number Baseefa02ATEX0224X/7

15 Description of the variation to the Equipment or Protective System

#### Variation 7.1

Alternative design of the well glass retaining device and the associated groove in the cover.

16 Report Number

None

17 Special Conditions for Safe Use

None additional to those listed previously

18 Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 Drawings and Documents

Number	Sheet	Issue	Date	Description
188-547	1	E	25-04-08	Type XB4 General Details



## SUPPLEMENTRY EC - TYPE EXAMINATION CERTIFICATE

Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC

- 3 Supplementary EC - Type Examination Certificate Number: **Baseefa02ATEX0224X/8**
- 4 Equipment or Protective System: **Type XB4 Xenon Beacon**
- 5 Manufacturer: **Cooper MEDC Limited**
- 6 Address: **Colliery Road, Pinxton, Nottingham, NG16 6JF**
- 7 This supplementary certificate extends EC – Type Examination Certificate No. **Baseefa02ATEX0224X** to apply to equipment or a protective system designed and constructed in accordance with the specification set out in the Schedule of this certificate and incorporates and supersedes all previous issues of the said certificate.
- 8 Baseefa, Notified Body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.
- The examination and test results are recorded in confidential Report No. **GB/BAS/ExTR10/0171/00**
- 9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
- EN60079-0: 2009                      EN60079-1: 2007                      IEC60079-31:2008**
- except in respect of those requirements listed at item 18 of the Schedule.
- 10 If the sign “X” is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- 11 This Supplementary EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- 12 The marking of the equipment or protective system shall include the following :

**Ⓔ II 2 GD      Ex d IIC T\* Ta -55°C to + \*\*°C Gb      Ex tb IIIC T\*\* Ta -55°C to + \*\*°C Db IP6X**

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. **0676**

Project File No. **10/0208**

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

### Baseefa

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.

*AP M. Power*  
**R S SINCLAIR**  
DIRECTOR  
On behalf of  
Baseefa



13

## Schedule

14

Certificate Number Baseefa02ATEX0224X/8

### 15 Description of Equipment or Protective System

The Type XB4 Beacon comprises a cylindrical enclosure base and cover manufactured from cast stainless steel or aluminium alloy. The cover is secured with M8 stainless steel screws of grade A4-80, and is fitted with a wellglass which may be provided with a wire guard.

The base is provided with a flat portion for up to three threaded cable entries.

The enclosure houses various internal arrangements as indicated below.

Up to two 10J xenon tubes and associated printed circuit board to form a type XB4 Xenon Beacon, with control electronics and terminals. In this form the Xenon Beacon is rated up to 110V d.c., 254V a.c.

A filament lamp rated up to 48V d.c., 254V a.c., 60/100W to form a type FB4 Luminaire.

Up to three fluorescent lamps, control electronics and ballasts rated up to 48V d.c., 240V a.c., 13W, 26W or 39W to form a type FL4 Luminaire.

Beacon	Watts	Temperature classification	Marked Temperature	Ambient temperature range	Cable Temperature Rise (K)
XB4	2x10J	T4	T135°C	-55°C to + 85°C	25
		T5	T100°C	-55°C to + 55°C.	
		T6	T85°C	-55°C to + 40°C.	
FB4	100	T3	T185°C	-55°C to + 55°C.	60
	60	T4	T135°C	-55°C to + 70°C	34
		T5	T100°C	-55°C to + 30°C	
FL4	39	T4	T135°C	-55°C to + 70°C	37
		T5	T100°C	-55°C to + 40°C	
	26	T4	T135°C	-55°C to + 85°C	29
		T5	T100°C	-55°C to + 55°C	
		T6	T85°C	-55°C to + 40°C	
	13	T4	T135°C	-55°C to + 85°C	26
		T5	T100°C	-55°C to + 55°C	
		T6	T85°C	-55°C to + 40°C	

Cable entry holes are provided as specified on the certified drawings for the accommodation of flameproof cable entry devices, with or without the interposition of a flameproof thread adapter. Unused entries are to be fitted with suitable certified flameproof stopping plugs.

The cable entry devices, thread adapters and stopping plugs shall be suitable for the equipment, the cable and the conditions of use and shall be certified as Equipment (not a Component) under an EC-Type Examination Certificate to Directive 94/9/EC.

When used in an explosive dust atmosphere the cable entry devices shall maintain the ingress protection of the enclosure

### 16 Report Number

Baseefa Certification Report GB/BAS/ExTR10/0171/00



---

**17 Special Conditions for Safe Use**

- 1 The flameproof cable entry device used with the equipment shall be suitable for the entry arrangement and maintain the ingress protection level IP6X.

**18 Essential Health and Safety Requirements**

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

**19 Drawings and Documents**

The drawings indicated below amalgamate the current design and previous variations, and supersede all previous issues.

Number	Sheet	Issue	Date	Description
188-646	1	A	20.08.10	General Assembly
188-646	2	A	20.08.10	Internal arrangements
188-646	3	A	20.08.10	Enclosure Details
188-647	1	A	20.08.10	Marking Details



**SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

**Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

- 3 Supplementary EC - Type Examination Certificate Number: **Baseefa02ATEX0224X/9**
- 4 Equipment or Protective System: **Type XB4 Xenon Beacon**
- 5 Manufacturer: **Cooper MEDC Limited**
- 6 Address: **Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG17 5FB**
- 7 This supplementary certificate extends EC – Type Examination Certificate No. Baseefa02ATEX0224X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

Baseefa Customer Reference No. **0676**

Project File No. **14/0046**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Baseefa Limited**


Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN



R S SINCLAIR

GENERAL MANAGER

On behalf of SGS Baseefa Limited

13 **Schedule**

14 **Certificate Number Baseefa02ATEX0224X/9**

15 **Description of the variation to the Equipment or Protective System**

**Variation 9.1**

Addition of an example wiring diagram and specifications for the optional in-line and end of line resistors. The existing ratings of the units are unaffected.

16 **Report Number**

GB/BAS/ExTR14.0018/00

17 **Specific Conditions of Use**

None additional to those listed previously

18 **Essential Health and Safety Requirements**

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 **Drawings and Documents**

Number	Sheet	Issue	Date	Description
188-646	1	B	07-01-14	General Arrangement XB4 et al.
188-646	2	B	07-01-14	General Arrangement XB4 et al.
188-646	3	B	07-01-14	General Arrangement XB4 et al.